

**Copy of the certificate regarding Water, Health & Sanitation issued by
Medical Officer, Primary Health Center**



PRIMARY HEALTH CENTER SHELA
SHELA, TALUKA-SANAND, AHMEDABAD
E-MAIL-phcshela.health.ahmedabad@gmail.com



नं./पी.अच.सी./sanitation./अरज.वशी, 60/2024

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 21/02/2024

It is certified that an inspection team headed by Dr S K Kapadia Medical Officer & Maheshbhai Patel(MPHS) from Primary Health Center Shela, Sanand, Ahmedabad inspected the NEW LDR INTERNATIONAL SCHOOL, OPP MAHER STREET, VIP ROAD, SHELA, AHMEDABAD on 21/03/2024 and on the basis of Water Test Report (Attached) bearing no 893/2023-2024 dated 21/02/2024 Of District Laboratory (Gujarat water supply & sewerage board, Ahmedabad) certified that the NEW LDR INTERNATIONAL SCHOOL, OPP MAHER STREET, VIP ROAD, SHELA, AHMEDABAD has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the State Govt.

This certificate is valid till one year

21/2/24
Medical Officer
PHC-SHELA

Signature with Seal:
Name :
Designation :

Dr. S. K. Kapadia
Medical Officer, Shela

To
NEW LDR INTERNATIONAL SCHOOL
OPP MAHER STREET, VIP ROAD,
AHMEDABAD






FOR, NEW LDR INTERNATIONAL SCHOOL

Chaitali
PRINCIPAL

LATE DIPTIBEN RAVAL MEMORIAL TRUST

25/1/24
P. Ravi
AUTHORISED SIGNATORY

Copy of the Water Examination Report

QF-DL/7.8/F-31																																																																																	
																																																																																	
DISTRICT LABORATORY Gujarat Water Supply & Sewerage Board AHMEDABAD																																																																																	
TC - 7119																																																																																	
Test Report																																																																																	
Name & Address of Customer *:- Parash Raval Managing Trustee New LDR International School Opp.Mehar Street VIP Road South Bopal Ahmedabad Ahmedabad Organisation: PVT																																																																																	
Customer Reference No. *:- 19/Feb/2024 Sample Submitted by : Customer Date of Sample Collection *:- 19-Feb-2024 Date of Sample Recolpt : 19-Feb-2024 Analysis Starting Date:-19-Feb-24 Analysis Completion Date:-19-Feb-24 ULR No.:TC711923000001337F Discipline : Chemical Testing, Group : Drinking Water																																																																																	
Test Report No.:893/2023-2024	Date Of Issue:-21-Feb-2024																																																																																
Sample ID : ACW-893 / 02-2024	Condition of Sample: Satisfactory																																																																																
Customer ID *:- Sample-1																																																																																	
Main Source *:- Ground Water	Source *:- Bore Water																																																																																
Location *:- New LDR International School Parisar																																																																																	
Village *:- Ahmedabad	Habitation *:-																																																																																
Taluka *:- Ahmedabad	District *:- Ahmedabad																																																																																
Latitude *:- 0	Longitude *:- 0																																																																																
Kindly find herewith the Analytical Results:-																																																																																	
Sample Type: Drinking Water																																																																																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 5%;">Sr.No.</th> <th style="width: 35%;">Parameter</th> <th style="width: 10%;">Unit</th> <th style="width: 30%;">Reference Method</th> <th style="width: 20%;">Analytical Value</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Colour</td> <td>Hazen</td> <td>APHA (24th Ed.2022), Method: 2120.C</td> <td>< 1</td> </tr> <tr> <td>2</td> <td>Turbidity</td> <td>NTU</td> <td>APHA (24th Ed.2022), Method: 2130.B</td> <td>5.67</td> </tr> <tr> <td>3</td> <td>pH at 25°C</td> <td></td> <td>APHA (24th Ed.2022) Method: 4500.H* B</td> <td>7.30</td> </tr> <tr> <td>4</td> <td>Conductivity at 25°C</td> <td>µS/cm</td> <td>APHA (24th Ed.2022) Method: 2510.B</td> <td>794</td> </tr> <tr> <td>5</td> <td>Total Dissolved Solids</td> <td>mg/L</td> <td>APHA (24th Ed.2022) Method: 2540.C</td> <td>508</td> </tr> <tr> <td>6</td> <td>Total Hardness (as CaCO₃)</td> <td>mg/L</td> <td>APHA (24th Ed.2022) Method: 2340.C</td> <td>172</td> </tr> <tr> <td>7</td> <td>Calcium (as Ca²⁺)</td> <td>mg/L</td> <td>APHA (24th Ed.2022) Method: 3500.Ca²⁺ B</td> <td>32</td> </tr> <tr> <td>8</td> <td>Magnesium (as Mg²⁺)</td> <td>mg/L</td> <td>APHA (24th Ed.2022) Method: 3500-Mg²⁺ B</td> <td>22</td> </tr> <tr> <td>9</td> <td>Chloride (as Cl⁻)</td> <td>mg/L</td> <td>APHA (24th Ed.2022) Method: 4500-Cl⁻ B</td> <td>190</td> </tr> <tr> <td>10</td> <td>Sulphate (as SO₄²⁻)</td> <td>mg/L</td> <td>APHA (24th Ed.2022) Method: 4500-SO₄²⁻ E</td> <td>50</td> </tr> <tr> <td>11</td> <td>Nitrate (as NO₃⁻)</td> <td>mg/L</td> <td>APHA (24th Ed.2022) Method: 4500-NO₃⁻ B</td> <td>-</td> </tr> <tr> <td>12</td> <td>Fluoride (as F⁻)</td> <td>mg/L</td> <td>APHA (24th Ed.2022) Method: 4500-F⁻ C</td> <td>0.91</td> </tr> <tr> <td>13</td> <td>Total Alkalinity (as CaCO₃)</td> <td>mg/L</td> <td>APHA (24th Ed.2022) Method: 2320.B</td> <td>96</td> </tr> <tr> <td>14</td> <td>Odour</td> <td></td> <td>IS 3025 (part-3)-2018 Second Revision</td> <td>Agreeable</td> </tr> <tr> <td>15</td> <td>Taste</td> <td></td> <td>IS 3025 (part-8)-1984 Reaffirmed 2012</td> <td>Agreeable</td> </tr> </tbody> </table>	Sr.No.	Parameter	Unit	Reference Method	Analytical Value	1	Colour	Hazen	APHA (24 th Ed.2022), Method: 2120.C	< 1	2	Turbidity	NTU	APHA (24 th Ed.2022), Method: 2130.B	5.67	3	pH at 25°C		APHA (24 th Ed.2022) Method: 4500.H* B	7.30	4	Conductivity at 25°C	µS/cm	APHA (24 th Ed.2022) Method: 2510.B	794	5	Total Dissolved Solids	mg/L	APHA (24 th Ed.2022) Method: 2540.C	508	6	Total Hardness (as CaCO ₃)	mg/L	APHA (24 th Ed.2022) Method: 2340.C	172	7	Calcium (as Ca ²⁺)	mg/L	APHA (24 th Ed.2022) Method: 3500.Ca ²⁺ B	32	8	Magnesium (as Mg ²⁺)	mg/L	APHA (24 th Ed.2022) Method: 3500-Mg ²⁺ B	22	9	Chloride (as Cl ⁻)	mg/L	APHA (24 th Ed.2022) Method: 4500-Cl ⁻ B	190	10	Sulphate (as SO ₄ ²⁻)	mg/L	APHA (24 th Ed.2022) Method: 4500-SO ₄ ²⁻ E	50	11	Nitrate (as NO ₃ ⁻)	mg/L	APHA (24 th Ed.2022) Method: 4500-NO ₃ ⁻ B	-	12	Fluoride (as F ⁻)	mg/L	APHA (24 th Ed.2022) Method: 4500-F ⁻ C	0.91	13	Total Alkalinity (as CaCO ₃)	mg/L	APHA (24 th Ed.2022) Method: 2320.B	96	14	Odour		IS 3025 (part-3)-2018 Second Revision	Agreeable	15	Taste		IS 3025 (part-8)-1984 Reaffirmed 2012	Agreeable	
Sr.No.	Parameter	Unit	Reference Method	Analytical Value																																																																													
1	Colour	Hazen	APHA (24 th Ed.2022), Method: 2120.C	< 1																																																																													
2	Turbidity	NTU	APHA (24 th Ed.2022), Method: 2130.B	5.67																																																																													
3	pH at 25°C		APHA (24 th Ed.2022) Method: 4500.H* B	7.30																																																																													
4	Conductivity at 25°C	µS/cm	APHA (24 th Ed.2022) Method: 2510.B	794																																																																													
5	Total Dissolved Solids	mg/L	APHA (24 th Ed.2022) Method: 2540.C	508																																																																													
6	Total Hardness (as CaCO ₃)	mg/L	APHA (24 th Ed.2022) Method: 2340.C	172																																																																													
7	Calcium (as Ca ²⁺)	mg/L	APHA (24 th Ed.2022) Method: 3500.Ca ²⁺ B	32																																																																													
8	Magnesium (as Mg ²⁺)	mg/L	APHA (24 th Ed.2022) Method: 3500-Mg ²⁺ B	22																																																																													
9	Chloride (as Cl ⁻)	mg/L	APHA (24 th Ed.2022) Method: 4500-Cl ⁻ B	190																																																																													
10	Sulphate (as SO ₄ ²⁻)	mg/L	APHA (24 th Ed.2022) Method: 4500-SO ₄ ²⁻ E	50																																																																													
11	Nitrate (as NO ₃ ⁻)	mg/L	APHA (24 th Ed.2022) Method: 4500-NO ₃ ⁻ B	-																																																																													
12	Fluoride (as F ⁻)	mg/L	APHA (24 th Ed.2022) Method: 4500-F ⁻ C	0.91																																																																													
13	Total Alkalinity (as CaCO ₃)	mg/L	APHA (24 th Ed.2022) Method: 2320.B	96																																																																													
14	Odour		IS 3025 (part-3)-2018 Second Revision	Agreeable																																																																													
15	Taste		IS 3025 (part-8)-1984 Reaffirmed 2012	Agreeable																																																																													
This Report is issued under the following terms & Condition:- 1. This report is referring only to the tested sample and for applicable parameter. 2. The sample will be destroyed after retention time unless otherwise specified specially. 3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law. 4. Please refer back page for IS 10500:2012 (2nd Revision) limits. 5. Disclaimer : Information marked by "*" is provided by the customer.																																																																																	
Checked By:  Ekta Dave(Analyst)	Issued By:  (Authorized Signatory)																																																																																
																																																																																	
End of the Test Report																																																																																	
O.W.No. DLA/ 1 of 2024, Dt. 1 / 2024 5th Floor, jalbhavan, Behind Town Hall, Ellisbridge, Ahmedabad-380006 Telephone No.:-9978441113 to 17 E-mail: jalbhavan.lab@gmail.com																																																																																	

FOR, NEW LDR INTERNATIONAL SCHOOL


 PRINCIPAL

LATE DIPTIBEN RAVAL MEMORIAL TRUST


 AUTHORIZED SIGNATORY